

DuPont[™] IntegraTec[™] MB 38

Modules for Open Platform

(previously dizzer XL 0.9 MB 38 W)

Key Features

Proven Multibore™ PES Fibers:

- Exceptional physical strength and chemical resistance.
- High colloidal particulate, bacteria and virus log removal rate.
- · Excellent filtration permeability.
- Optional coagulation can enhance the removal of algae and organics.

Optimized Module Design:


- · Open platform design to fit customer built skids.
- · Robust materials for long lifetime.
- Easy installation and low maintenance.
- · All wetted parts corrosion free.


Key Applications

- · Municipal drinking water.
- · Industrial utility water.
- · Water reuse.
- Ideal for small systems.

Module Specification

| General | | |
|---|--------------------|---------------------|
| Part Number / GMID | IN-0070 / 12071518 | |
| Mode of Filtration | In-Out Pressurized | |
| Membrane Type | Multibore™ | |
| Membrane Material | PESm | |
| Nominal Membrane Pore Size | 0.02 μm | |
| Module Operating Process | Dead-end | |
| Housing Material | PVC-U, white | |
| End Cap Material | PVC-U, grey | |
| End Cap Coupling Material | SS (EPDM sealing) | |
| Dimensions | | |
| Active Membrane Area | 38 m² | 409 ft ² |
| Module Length (L) | 985 ± 1.5 mm | 38.8 inch |
| Distance Top / Bottom Feed Port (L1) | 1,099 ± 3.0 mm | 43.3 inch |
| Length with End Caps (L2) | 1,179 ± 3.0 mm | 46.4 inch |
| Module Diameter (A) | 250 ± 1.5 mm | 9.8 inch |
| Distance Feed Top Port - Filtrate Port (B) | 190 ± 1.5 | 7.5 inch |
| Outer Diameter End Cap Coupling Maximum (C) | 295 mm | 11.6 inch |
| Protruding Part of the Port (E) | 40 ± 1 mm | 1.6 inch |
| Filtrate / Backwash Port (D) | 50.8 mm | 2 inch |
| Weight and Volume | | |
| Shipping Weight | 34 kg | 75 lbs. |
| Weight Empty | 34 kg | 75 lbs. |
| Weight Filled | 66 kg | 146 lbs. |
| Hold-Up Volume Feed (CIP) | 14 L | 3.7 gal |
| Hold-Up Volume Membrane Structure (CIP) | 10 L | 2.6 gal |
| Hold-Up Volume Filtrate (CIP) | 11 L | 2.9 gal |
| | | |











Suggested Operating Conditions

| General | Details | | |
|-----------------------------|---------------------------------|---------------------------------|--|
| Operating Temperature Range | 1 - 40 °C | 34 - 104 °F | |
| Operating pH | 3 - 11 | | |
| Cleaning pH | 1 - 13 | | |
| Typical Filtration TMP | 0.1 - 0.6 bar | 1.5 - 8.7 psi | |
| Typical Backwash TMP | 0.3 - 2.0 bar | 4.4 - 29.0 psi | |
| Backwash Flux | 230 L/(m²h) | 135 gfd | |
| Backwash Flow | $8.7 \text{ m}^3\text{h}$ | 38.3 gpm | |
| Operating Limits (Maximum) | | | |
| Rate of Temperature Change | 5 °C/min | 9 °F/min | |
| Inlet Pressure (20 - 40 °C) | 5 bar | 73 psi | |
| Rate of Pressure Change | 0.5 bar/sec | 7.3 psi/sec | |
| Filtration TMP | 1.5 bar | 22 psi | |
| Backwash TMP | 3.0 bar | 44 psi | |
| Filtration Flux | 180 L/(m²h) | 106 gfd | |
| Filtration Flow | 6.8 m³h | 29.9 gpm | |
| Backwash Flux | 300 L/(m²h) | 176 gfd | |
| Particle Size | 300 µm | | |
| Exposure NaOCl | ≤ 250,000 ppm x h (at pH ≥ 9.5) | ≤ 250,000 ppm x h (at pH ≥ 9.5) | |
| Concentration NaOCl | 500 ppm | | |

General Information

- Avoid any abrupt pressure variations during start-up, operation, shutdown, cleaning or other sequences to prevent possible membrane damage. The maximum pressure change allowable is 0.5 bar/s.
- For assembly please refer to the <u>DuPont™ IntegraTec™</u>

 <u>Pressurized UF In-Out P Series Modules for Open Platforms</u>

 <u>Assembly Instructions (Form No. 45-D02231-en).</u>
- If operating limits and guidelines given in this bulletin are not strictly followed, any warranty will be null and void.
- To control biological growth during extended system shutdowns, a storage solution must be introduced into the membrane modules. Detailed information is given in the <u>DuPont™ IntegraTec™ Pressurized UF Out-In Module Preservation Instruction Manual</u> (Form No. 45-D02946-en).

Regulatory Note

- Certified drinking water modules require specific conditioning procedures prior to producing potable water. For operating parameters, please refer to the <u>DuPont™ IntegraTec™</u> <u>Pressurized UF In-Out P Series Process and Design Guidelines</u> (Form No. 45-D02234-en).
- Drinking water modules may be subjected to additional regulatory restrictions in some countries. Please check local regulatory guidelines and application status before use.
- Flushing needs to be done according to the <u>DuPont™</u>
 <u>IntegraTec™ Pressurized UF Out-In Module Rinsing Procedure</u>
 (Form No. 45-D02947-en).



All information set forth herein is for informational purposes only. This information is general information and may differ from that based on actual conditions. Customer is responsible for determining whether products and the information in this document are appropriate for Customer's use and for ensuring that Customer's workplace and disposal practices are in compliance with applicable laws and other government enactments. The product shown in this literature may not be available for sale and/or available in all geographies where DuPont is represented. The claims made may not have been approved for use in all countries. Please note that physical properties may vary depending on certain conditions and while operating conditions stated in this document are intended to lengthen product lifespan and/or improve product performance, it will ultimately depend on actual circumstances and is in no event a guarantee of achieving any specific results. DUPONT ASSUMES NO OBLIGATION OR LIABILITY FOR THE INFORMATION IN THIS DOCUMENT. References to "DuPont" or the "Company" mean the DuPont legal entity selling the products to Customer unless otherwise expressly noted. NO WARRANTIES ARE GIVEN; ALL IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY EXCLUDED. No freedom from infringement of any patent or trademark owned by DuPont or others is to be inferred.